

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Independently mounted automatic controls for use with heating appliances
Name and address of the applicant	Psicontrol N.V. Steverlyncklaan 15 Ieper, 8900 Belgium
Name and address of the manufacturer	Vaillant GmbH Berghauser Str. 40 Remscheid, 42859 Germany
Name and address of the factory	Vaillant GmbH Berghauser Str. 40 Remscheid, 42859 Germany
<i>Note: When more than one factory, please report on page 2</i>	<input type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	VRC 720, VRC 720/2, VRC 720/3, VRT 380, VRT 380/2, VR92, VR92/2, VR92/3: 9-24 VDC 0.05 A, 0 to 60 °C. VRC 720f, VRC 720f/2, VRC 720f/3, VRT 380f, VRT 380f/2, VR92f, VR92f/2, VR92f/3: 4x1.5 VDC LR6, 0.05 A, 0 to 45 °C.
Trademark / Brand (if any)	Vaillant
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	VRC 720, VRC 720/2, VRC 720/3, VRC 720f, VRC 720f/2, VRC 720f/3, VRT 380, VRT 380/2, VRT 380f, VRT 380f/2, VR92, VR92/2, VR92/3, VR92f, VR92f/2, VR92f/3
Additional information (if necessary may also be reported on page 2)	The product fulfils the requirements of IEC 60335-2-102:2017, clause 30 used in conjunction with IEC 60335-1:2020. <input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60730-2-9:2015, IEC 60730-2-9:2015/AMD1:2018, IEC 60730-2-9:2015/AMD2:2020 National differences: EU Group Differences, CA, US
As shown in the Test Report Ref. No. which forms part of this Certificate	2273843.50 (consisting of sub reports with suffixes A, B, C, D, E, F and G).

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands

Date: 2023-03-23

Signature: H.R.M. Barends