

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	Heat pump
Name and address of the applicant	Vaillant GmbH Berghauser Strasse 40, 42859 Remscheid GERMANY
Name and address of the manufacturer	Vaillant GmbH Berghauser Strasse 40, 42859 Remscheid GERMANY
Name and address of the factory	Vaillant GmbH Berghauser Strasse 40, 42859 Remscheid GERMANY
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	<input type="checkbox"/> Additional Information on page 2 Power supply main circuit: 3 N PE ~ 400V Power supply control circuit: AC 230 V, Rated frequency: 50 Hz, Refrigerant: R410A, IP 10B *)
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	CTF Stage 1
Model / Type Ref.	VWF 57/4, VWF 58/4, VWF 87/4, VWF 88/4, VWF 117/4, VWF 118/4, VWF 157/4, VWF 197/4, VWF 57/4 S1, VWF 58/4 S1, VWF 87/4 S1, VWF 88/4 S1, VWF 117/4 S1, VWF 118/4 S1, VWF 157/4 S1, VWF 197/4 S1 **)
Additional information (if necessary may also be reported on page 2)	*) further information on ratings, see test report **) Versions...S1 without backup-heater  <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60335-1:2010 IEC 60335-2-40:2013 IEC 62233:2005
As shown in the Test Report Ref. No. which forms part of this Certificate	222205-AS9-1

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierung Produkte / Certification Products



Date: 2016-12-19

Signature:

M. Tasotti