

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Ventilation unit
(Ventilation appliance with heat recovery)

Name and address of the applicant

Vaillant GmbH
Berghauser Strasse 40, 42859 Remscheid
GERMANY

Name and address of the manufacturer

Vaillant GmbH
Berghauser Strasse 40, 42859 Remscheid
GERMANY

Name and address of the factory

Vaillant GmbH
Berghauser Strasse 40, 42859 Remscheid
GERMANY

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Additional Information on page 2

AC 230 V, 50 Hz, IP 10B, max. allowed ambient temp.: 40°C,
Pmax. 500 Pa
a) 342 W, b) 170 W, c) 84 W

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 1

Model / Type Ref.

a) VAR 360/4, VAR 360/4 E
b) VAR 260/4, VAR 260/4 E
c) VAR 150/4 R, VAR 150/4 L

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60335-1:2010; 60335-1:2010/AMD1:2013
IEC 60335-1:2010/AMD2:2016
IEC 60335-2-40:2018
IEC 62233:2005

As shown in the Test Report Ref. No. which forms part of this Certificate

290784-TL2-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2022-03-03

Signature:

A. Fabian